

AKOLA MUNICIPAL CORPORATION, AKOLA

Outward no./AMC/Firefighting/111/2022
Firefighting and Emergency Service
Akola Municipal Corporation, Akola
Date :19/05/2022

No Objection Certificate (temporary)

To,
Shri.Prasad Suresh Pathak (Principal)
Jubilee English High School Kumbhari,
Akola.

Subject:- Receiving a temporary certificate of firefighting measures from the fire department.

According to Maharashtra Land Revenue officer Records and Register Village: - Kumbhari Taluka: -Akola District: - Akola Gut Number & Subdivision - 237 Occupant Methods Occupant Class-1 Area and Assessment Account No. 53 Name of Occupant: - on behalf of Akola Education Society Anant Vasudev Digambar Area 2.96, size 2882, modification number 33, According to this, the height of this educational building is 10 meters and the first and second floor.

Accordingly, temporary firefighting measures are being given as follows.

1. No-fire certificate will be issued only after making complete arrangements regarding fire safety.
2. It will be mandatory for the licensed agencies registered by the Hon'ble Director, Maharashtra Fire Services Directorate, Mumbai, to inspect the fire protection system twice a year, in January and July.
3. The following fire extinguishing measures should be taken at the place of business / construction.
4. Fire extinguishers and equipment should be in accordance with ISI specifications.
5. Demonstration to Akola Municipal Corporation Fire Department after fully operational system.
6. Emergency fire exits and fire signages should be arranged.
7. It is mandatory to install extinguishers where necessary.
8. The water tank at this place should not be misused. The water level in the tank should be completely filled.
9. At this point, it will be mandatory for you to hire firefighters.
10. In case of any accident at this place, Akola Municipal Corporation will not have any responsibility.
11. In case of any fire due to lack of the above suggested conditions, you will be solely responsible for it.
12. If unauthorized construction is done at this place, you will be fully responsible for it.
13. Documentation of ownership of the premises, If the documents submitted are found to be false or misleading, the certificate will be deemed revoked.
14. Compliance with the Maharashtra Fire Prevention and Protection Act, 2006 and UDCPR-2020 will be mandatory.
15. You are being given a temporary certificate subject to fulfilling the above conditions.

(Temporary No Objection Certificate is valid from 19/05/2022 to 18/04/2023.)





(Apply the given measures)

Sr.No.	Measures	Which to do	Which should not
1	Fire prevention		
2	Fire extinguishers	Required	
3	Hose pipe coil	Required	
4	Arid path		not Required
5	Moisture path		not Required
6	Pipe coming down		not Required
7	Yard plumbing		not Required
8	Types of devices		
9	Automatic sprinkler system		not Required
10	Manual Electric Fear Information System		not Required
11	Automated Investigation and Fear Information System		not Required
12	Water supply (in liters)		
13	Underground water storage tank of 1,50,000 liters		not Required
14	Construction of 15000 liter tank on the terrace	Required	
15	Pump capacity (in liters)		
16	Pumps with a pressure of at least 0.3 N / m at the level near the water storage tank 900 l p m And 600 l p m 7.5 Hp (fire pump) stand by diesel pump required.		

(Note: - By CFO order the total fees is Rs. 20,000. out of which Rs. 10,000 Receipt of 128 x 55 Retrieved on 20/05/2022. The remaining fees of Rs. 10,000 will have to be paid at the time of providing final No Objection Certificate.)



On the basis of Original instrument produced before me, This is certified to be translated from Marathi to English.



Signature

Shishir A. Deshpande
25/5/2022

Chief Fire Officer,
Akola Municipal Corporation Akola

Certified that this document / Affidavit contains Pages From 1 to *Two pages*

NOTARY
GOVT. OF INDIA
Opp. Civil Court
AKOLA (Mah.)
Mob 9823091377

अकोला महानगरपालिका अकोला



जा.क्र./अमनपा/अग्निशमन/111/2022

अग्निशमन व आगिबाणी सेवा

अकोला महानगरपालिका, अकोला

दिनांक 19/05/2022

नाहरकत प्रमाणपत्र (तात्पुरते)

प्रति,

श्री. प्रसाद सुरेश पाठक (प्राचार्य)

ज्युबिली इंग्लिश हायस्कूल,

कुंभारी, अकोला.

विषय:- अग्निशमन विभागातील अग्निशमन उपाययोजनांचे तात्पुरते प्रमाणपत्र मिळण्याबाबत.

संदर्भ:- दिनांक 18/05/2022 रोजी अर्जानुसार

महाराष्ट्र जमीन महसूल अधिकारी अभिलेख आणि नोंदवह्या नुसार गाव:- कुंभारी तालुका:- अकोला जिल्हा :- अकोला. गट क्रमांक व उपविभाग - २३७ भोगवटादार पद्धती भोगवटादार वर्ग - १. क्षेत्रफळ व आकारणी खाते क्र. ५३. भोगवटादाराचे नाव:- अकोला एजुकेशन सोसाइटी तर्फे अनंत वासुदेव दिगंबर क्षेत्र २.९६ आकार २८८२ फेरफार क्र. ३३ अनुसार या शैक्षणिक इमारतीची उंची १० मीटर आहे व पहिला व दुसरा मजला आहे. त्यानुसार खालील प्रमाणे अग्निशमन तात्पुरते उपाययोजना देण्यात येत आहे.

1. अग्निसुरक्षा संबंधी दिलेली संपूर्ण व्यवस्था केल्यावरच नाहरकत प्रमाणपत्र देण्यात येईल.
2. अग्निसुरक्षा व्यवस्थेचे परीक्षण मा. संचालक महाराष्ट्र अग्निशमन सेवा संचालनालय मुंबई यांनी नोंदणीकृत केलेले अनुज्ञाप्तीधारक अभिकरणांकडून जानेवारी व जुलै असे वर्षातून दोनवेळा करून घेणे बंधनकारक राहील.
3. सदर व्यवसायाच्या / बांधकामाच्या ठिकाणी खालील अग्निशमन उपाययोजना करण्यात यावी.
4. फायर एक्सिंग्विशर्स व उपकरणे आय.एस.आय.चे स्पेसिफिकेशन प्रमाणे असावेत.
5. यंत्रणा पूर्णपणे कार्यान्वित केल्यानंतर अग्निशमन विभाग महानगरपालिका अकोला यांना प्रात्यक्षित दाखविणे.
6. Emergency Fire Exit व Fire Signages ची व्यवस्था करावी.
7. आवश्यक त्या ठिकाणी अग्निशामके (Extinguishers) लावणे अनिवार्य आहे.
8. सदर ठिकाणी असलेल्या (फायर बॉटर टँक) पाण्याच्या टाकीचा दुरुपयोग करू नये टाकीतील पाण्याची पातळी पूर्णतः भरलेली असावी.
9. सदर ठिकाणी आपण फायर यंत्रणेसंबंधी तज्ञ कर्मचारी नेमणे बंधनकारक राहील.
10. सदर ठिकाणी कोणतीही दुर्घटना घडल्यास महानगरपालिका अकोला ची कोणतीही जबाबदारी राहणार नाही.

11. वरील प्रमाणे सुचविलेल्या अवस्थेअभावी आगीची कोणतीही घटना घडल्यास याची सर्वस्वी जबाबदारी आपली राहिल.
12. सदर ठिकाणी अनधिकृत बांधकाम केल्यास त्याची संपूर्ण जबाबदारी आपली राहिल.
13. जागेची मालकी कागदपत्रे सादर केलेली कागदपत्रे प्रमाणपत्र खोटी अथवा दिशाभूल आढळल्यास नाहरकत प्रमाणपत्र रद्द समजण्यात येईल.
14. महाराष्ट्र आग प्रतिबंधक व जीवसंवरक्षक अधिनियम, 2006 आणि UDCPR-2020 चे पालन करणे बंधनकारक राहिल.
15. वर नमूद अटीची पूर्तता करण्याचे अधीन राहून आपणास Provisional नाहरकत प्रमाणपत्र देण्यात येत आहे.

(तात्पुरते नाहरकत प्रमाणपत्राची वैधता दिनांक 19/5/22 ते 18/4/23 पर्यंत आहे.)

(हि दिलेली उपाययोजना करावी.)

अ.क्र.	उपाययोजना	कोणती करावी	कोणती करू नये
1.	आग प्रतिबंधक		
2.	अग्निशामक यंत्रे	आवश्यक	
3.	होज पाईप ची गुंडाळी	आवश्यक	
4.	शुष्क उन्मार्ग		आवश्यक नाही
5.	आर्द उन्मार्ग		आवश्यक नाही
6.	खाली पाईप येणारा		आवश्यक नाही
7.	वार्ड नळखांब		आवश्यक नाही
8.	यंत्राचे प्रकार		
9.	स्वयंचलित तुषार यंत्रणा		आवश्यक नाही
10.	हस्तचलित इलेक्ट्रिक भय सुचना यंत्रणा		आवश्यक नाही
11.	स्वयंचलित तपास व भय सुचना यंत्रणा		आवश्यक नाही
12.	पाणी पुरवठा (लिटर मध्ये)		
13.	पाणी साठविण्याची भूमिगत 1,50,000 लिटर ची टाकी		आवश्यक नाही
14.	गच्चीवरील पाण्याची टाकी 15,000 लिटर ची टाकी बांधणे	आवश्यक	
15.	पंपाची क्षमता (लिटर मध्ये)		
16.	पाणी साठविण्याच्या गच्चीच्या टाकीजवळ पातळीवर किमान 0.3 एन. /एम. एम. इतका दाब असलेल्या पंप 900 lpm and 600 lpm 7.5 Hp (अग्निशमन पंप) standby diesel pump required.		

(टीप:- CFO यांच्या आदेशाने एकूण शुल्क 20,000/- रु. होते. त्यामधील 30,000/- रु. या पावती 138X55 दि. 20/5/22 अनुसार घेण्यात आले आहे. उर्वरित शुल्क 10,000/- रु. अंतिम नाहरकत प्रमाणपत्र घेते वेळेस भरावे लागेल.)




मुख्य अग्निशमन अधिकारी
अकोला महानगरपालिका, अकोला